

Idaho Maximum Security Institution
Kuna, Idaho
Replace Perimeter Detection System and CCTV Enhancements
DPW Project # 13-060

ADDENDUM #3

Related to the specifications:

A3.1 At BP1, second paragraph change "the Project within 150 consecutive calendar days" to "the base bid Project within 180 consecutive calendar days".

A3.2 At FPCC-37, Paragraph "Time for Performance and Liquidated Damages" change "the Contract within one hundred and fifty (150) consecutive calendar days" to "the base bid Contract within hundred and eighty (180) consecutive calendar days".

A3.3 At FPCC-47, Notice to Proceed, 1st paragraph change "the work within 150 consecutive calendar days" to "the base bid work within 180 consecutive calendar days".

A3.4 At 01100, SUMMARY, Paragraph 1.7.J.1, change "substantial completion 150 calendar days" to "substantial completion of base bid work 180 consecutive calendar days".

A3.5 At 01230, ALTERNATES, Paragraph 3.1.A. add a new sub-paragraph as follows:

3.1.A.2 No contract time will be added if this alternate is accepted.

A3.6 At 01230, ALTERNATES, Paragraph 3.1.B. add a new sub-paragraph as follows:

3.1.B.2 30 consecutive calendar days will be added to the contract time if this alternate is accepted. Contract time added for this alternate will be concurrent with contract time added for any other alternate.

A3.7 At 01230, ALTERNATES, Paragraph 3.1.C add a new sub-paragraph as follows:

3.1.C.2. 60 consecutive calendar days will be added to the contract time if this alternate is accepted. Contract time added for this alternate will be concurrent with contract time added for any other alternate.

A3.8 At 01230, ALTERNATES, Paragraph 3.1.D add a new sub-paragraph as follows:

3.1.D.2. No contract time will be added if this alternate is accepted.

A3.9 At 01230, ALTERNATES, Paragraph 3.1.E add a new sub-paragraph as follows:

3.1.E.2. 45 consecutive calendar days will be added to the contract time if this alternate is accepted. Contract time added for this alternate will be concurrent with contract time added for any other alternate.

A3.10 At 01230, ALTERNATES, Paragraph 3.1.F add a new sub-paragraph as follows:

3.1.F.2. No contract time will be added if this alternate is accepted.

Related to the drawings:

None

Related to Questions of Bidders

A3.11 Is the razor coil on top of the new taut wire fence double coil? - Yes

A3.12 There are 2 different specifications for the herbicide and aggregate ground cover. Could you clarify which one is relevant? - Requirements of 11191 take precedence

A3.13 When system manufacturer requirements differ from with the plans and specs, which takes precedent? - Refer to guidance contained in the bid documents for clarification.

A3.14 Page X2.02, What is the purpose of the note 5 labeled by the gate operator referring to removing existing management fence? - The existing management fence intersects the sallyport at the point noted - see 1/X2.02 at the same location and Keynote 21.

A3.16 Is there sidewalk that needs to be demolished as stated in the demolition specs? I don't see any. - Except for utility cuts in sidewalks - No.

A3.17 Does the 3.4 section on Fence Grounding refer only to new posts installed? Is the fence currently grounded? - No, it applies to the entire fence. No, the fence is not currently grounded.

A3.18 Regarding Fence Grounding Installer Qualifications: The nearest qualified installer is in Pendleton OR. Is there an alternative qualification? - We will accept grounding by the listed licensed electrician.

A3.19 Is it correct that the fence fabric only is for the upper 6' of the 12' stand-alone sensor fence as noted on X3.02? - Yes

A3.20 Can the project time for the base bid be extended beyond 150 days - we feel that is not enough time to complete the work of the base bid? Will contract time be added for the work of the alternates? (paraphrased) - See above clarification.

A3.21 Can you advise the camera mounting by location (paraphrased) - In the base bid, all but one camera is pole mounted and the exception is parapet mounted. In Alternate 1, all are pole mounted. In Alternate 2B, interior cameras... approximately 60% are wall mount, approx 40% are ceiling mount. Exterior cameras in 2B are 6 pole mount, 1 wall mount and 2 parapet mount.