



C. L. "BUTCH" OTTER  
Governor  
ROBERT L. GEDDES  
Director  
JAN P. FREW  
Administrator

# State of Idaho

Department of Administration  
Division of Public Works

502 North 4th Street  
P.O. Box 83720  
Boise, ID 83720-0072

Telephone (208) 332-1900 or FAX (208) 334-4031  
Design and Construction  
Facilities Services  
<http://dpw.idaho.gov>

November 23, 2016

## ADDENDUM NUMBER ONE

TO: Proposing HVAC Controls Design-Builders

FROM: Martin Santoyo, Project Manager *MS.*  
Division of Public Works

SUBJECT: DPW PROJECT NO. 17092, Requests for Qualifications, dated November 9, 2016  
**Replace DDC System, Shields Building**  
College of Southern Idaho (CSI)  
Twin Falls, Idaho

The following is additional information for the above referenced project:

**Clarification:** The agency currently has an existing controls system and the new system must be tied into their existing system; therefore, the HVAC controls platform must be the StruxureWare System. Other systems such as Automated Logic will not be allowed.

**End 17092 Addendum Number One**