

ORGANIZED 1904

Nampa & Meridian Irrigation District

1503 FIRST STREET SOUTH
FAX #208-463-0092

NAMPA, IDAHO 83651-4395
nmid.org

OFFICE: Nampa 208-466-7861
SHOP: Nampa 208-466-0663

August 5, 2024

Marty Vizcarra
Idaho State University
921 8th Ave STOP 8219
Pocatello ID 83209

RE: Land Use Change Application – Idaho State University AZ; SEC 18 3N 1E

To Whom It May Concern:

Enclosed you will find a Land Use Change Application to file with the Irrigation District for its review on the above-referenced development. **Please note the District now requires three (3) sets of plans & a PDF format of Civil Engineer & Landscape Architecture drawings.**

If this development includes a pressurized urban irrigation system (PUIS), please also fill out the enclosed PUIS questionnaire. I encourage you to coordinate with this office on specifications for and installation of the pressure system.


Please submit the completed application, three sets of plans with pdf format, and payment to the District's main office at 1503 First Street South Nampa, ID 83651. If time is of the essence, I recommend paying by **cashier's check, money order or cash**. Applications submitted with company or personal checks will not be processed until the check has cleared.

If you have any questions please feel free to call me at the District's shop, 208-466-0663.


Sincerely,

David T. Duvall
Asst. Water Superintendent
Nampa & Meridian Irrigation District
DTD/eol

Cc: Office/ file
S. Pardew
A. Wolfe



APPROXIMATE IRRIGABLE ACRES
RIVER FLOW RIGHTS - 23,000
BOISE PROJECT RIGHTS - 40,000



Nampa & Meridian Irrigation District

1503 FIRST STREET SOUTH
FAX #208-463-0092

NAMPA, IDAHO 83651-4395
nmid.org

OFFICE: Nampa 208-466-7861
SHOP: Nampa 208-466-0663

August 5, 2024

City Clerk's Office
City of Meridian
33 E. Broadway Avenue, Suite 102
Meridian, ID 83642-2619

RE: H-2024-0027/ Idaho State University AZ; SEC 18 3N 1E

To Whom It May Concern:

Nampa & Meridian Irrigation District (NMID) requires a filed Land Use Change Application to review prior to final platting.

All private laterals and waste ways must be protected. The Districts Hunter Lateral courses through this property. The Districts easement for the Hunter Lateral at this location is a minimum of forty feet (40') total, twenty feet (20') each side.


This easement must be protected. Any encroachment without a signed License Agreement and approved plan before construction is unacceptable.

All municipal surface drainage must be retained on site. If any municipal surface drainage leaves the site, NMID must review drainage plans. Developer must comply with Idaho Code 31-3805. Please feel free to contact me for further information.

Sincerely,

David T. Duvall
Asst. Water Superintendent
Nampa & Meridian Irrigation District
DTD /eol

Cc: Office/ file
S. Pardew
A. Wolfe
Applicant



APPROXIMATE IRRIGABLE ACRES
RIVER FLOW RIGHTS - 23,000
BOISE PROJECT RIGHTS - 40,000